



ಪ್ರಾಥಮಿಕ ಆರೋಗ್ಯ ಕೇಂದ್ರ
ಐವರಕಂಡಪುರ ಹೆಸರಘಟ್ಟ ಬೆಂಗಳೂರು ಉತ್ತರ ಬೆಂಗಳೂರು ನಗರ ಜಿಲ್ಲೆ ಬೆಂಗಳೂರು-560089
ಈ-ಮೇಲ್ : phchesaraghatta@gmail.com PH : 080 28466418.

ANNEXURE C

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No:PHC/HGT/89/2024-25

Date: 12.03.2025

It is certified that an inspection team headed by DR. RATHNAPRABHA. R, MEDICAL OFFICER, PRIMARY HEALTH CENTER, HESARAGHATTA, inspected **JNANA ACADEMY, # 57(old), 57/1, Tharabanahalli, Hesaraghatta Main Road, Bengaluru - 560 090**, run by **SRI JNANAGIRI EDUCATIONAL TRUST ®** on 12.03.2025 and on the basis of Water Test Report (attached), bearing no PHI/Water/BAC/2500/24-25 dated 10.03.2025 of office of the Joint Director, Public Health Institute, Bengaluru – 560001 (PHI Lab) certified that the **JNANA ACADEMY**, has safe drinking water facilities for the students and members of staff of the institution. School also maintains the Hygienic Sanitation condition in the school building and the campus as per the norms prescribed by the Central/State/U.T Government.

This certificate is valid for a period of 1 years

Signature with seal

ವೈದ್ಯಾಧಿಕಾರಿಗಳು

ಪ್ರಾಥಮಿಕ ಆರೋಗ್ಯ ಕೇಂದ್ರ ಹೆಸರಘಟ್ಟ,
ಬೆಂಗಳೂರು ಉತ್ತರ.ತಾ.ಬೆಂಗಳೂರು ನಗರ ಜಿಲ್ಲೆ,
ಬೆಂಗಳೂರು-560089

Name: DR. RATHNAPRABHA. R

Designation: MEDICAL OFFICER

Name & Address of the office/department: PRIMARY HEALTH CENTER

HESARAGHATTA,BENGALURU-560090

To

**JNANA ACADEMY,
OLD NO. 57, NEW NO 57/1,
THARABANAHALLI,
HESARAGHATTA MAIN ROAD,
BENGALURU – 560090.
KARNATAKA STATE**

(TRANSLATION FROM KANNADA VERSION TO ENGLISH VERSION)

LOGO OF GOVERNMENT OF KARNATAKA

PRIMARY HEALTH CENTER

Aiwarkandapura Hesaraghatta Bengaluru North Bengaluru City District Bengaluru -560089

E-mail : phchesaraghatta@gmail.com PH : 080 28466418

ANNEXURE C

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITON
CERTIFICATE

No. PHC/HGT/89/2024-25

Date: 12.03.2025

It is certified that an inspection team headed by DR. RATHNAPRABHA. R, MEDICAL OFFICER, PRIMARY HEALTH CENTER, HESARAGHATTA, inspected the JNANA ACADEMY, OLD NO. 57, NEW NO. 57/1, THARABANAHALLI, HESARAGHATTA MAIN ROAD, BENGALURU – 560090 run by SRI JNANAGIRI EDUCATIONAL TRUST ® on 12.03.2025 and on the basis of Water Test Report (attached), bearing no PHI/Water/BAC/2500/24-25 dated 10-03-2025 of Office of the Joint Director, Public Health Institute, Bengaluru – 560 001 (PHI Lab) certified that the JNANA ACADEMY, has safe drinking water facilities for the students and members of staff of the institution. School also maintains the Hygienic Sanitation condition in the School building and the campus as per the norms prescribed by the Central/State/U.T Government.

This certificate is valid for a period of 1 years.

Sd/-

Signature with seal:

SEAL

MEDICAL OFFICER, PRIMARY HEALTH CENTER,
Hesaraghatta Bengaluru North Bengaluru City
District Bengaluru -560089

Name : DR. RATHNAPRABHA. R

Designation : MEDICAL OFFICER

Name & Address of the office/department : PRIMARY HEALTH CENTER,
HESARAGHATTA, BENGALURU-560090

To

JNANA ACADEMY,
OLD NO. 57, NEW NO. 57/1,
THARABANAHALLI,
HESARAGHATTA MAIN ROAD,
BENGALURU – 560090.
KARNATAKA STATE

ATTESTED BY ME

RATNA. N. B.Com., LL.B.,
Advocate & Notary Public
GOVT. OF INDIA



TRANSLATED BY ME :

B.K

GOVERNMENT OF KARNATAKA

No:PHI/Water/BAC/ 2500/24-25

Office of the Joint Director
Public Health Institute
Bengaluru - 560 001

Dated: 10-03-2025

Report of Bacteriological analysis of Water/Effluent sample

Sample No.	Source & Particulars of Water Sample	Opinion				
		M.P.N Count	Plate Count	D.C Test	S.P.P	N.S.P.P & FC.
Principal Thana Academy # 57/1 Thasabana Halli Hesaragatta Main Road Bengaluru-90	RO water	Nil	-	-	SPP	-
<p>Note:</p> <p>M.P.N Count: Most probable number of Bacteria per 100ml of Water</p> <p>D.C Test: Differential Colliform test</p> <p>Plate Count: Plate Count per ml of sample</p> <p>SPP: Water is satisfactory for Potable purpose</p> <p>NSPP: Water is not satisfactory for Drinking purpose</p> <p>NSPP & FC: Water is not satisfactory for Drinking purpose and E.Coli found</p>						

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE
Bengaluru

(PTO)

For Joint Director (Labs)
Public Health Institute
Bengaluru - 560 001
Seeshan Road K.R. Circle

Advice:

1. Sample.....
Need effective chlorination before use
2. Sample.....

Need to avoid possible source of faecal contamination and effective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform count per 100ml	E coli count per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More

11-84 - 11-84